

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0328:142 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Potter Electric Signal Co, 2081 Craig Rd., St. Louis, MO 63146
Contact: *Brad Serangeli (800) 325-3936 Fax (314) 878-7264

DESIGN: Model PFC-100RC local fire alarm control unit for releasing device service. All circuits except for the battery terminals and AC input terminals are power limited. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary: 120V, 60Hz, 0.83A
Secondary: 24 VDC Nominal

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for releasing device service when used with separately listed compatible initiating and indicating devices.

*Rev. 06-20-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 14, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager